



NOTES:

1. Fuses: Class CC, 600 VAC, 15 Amps, current limiting time-delay UL listed, 200kA VAC RMS Sym. interrupting Rating; Limitron Class CC FNQ-R-15 or approved equal.
2. Single-Pole In-Line Fuse Holder with Solid Breakaway Option for impact separation: Rated 30A, 600V; Limitron HEB-AW-RLC-J for the fused disconnect and HET-AW-RLC=J having a permanently installed solid neutral (for the non-fused disconnect), or approved equal.
3. Cord must be SOW or S00W type with a 600V rating, min 12 AWG.

RRFB Pole Wiring Detail AC Powered

REVISION & DATE



ARLINGTON COUNTY, VIRGINIA
DEPARTMENT OF ENVIRONMENTAL SERVICES

DRAWING NO.
83-02